

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 175

Dated: 07/04/2025

It is certified that an inspection team headed by Kishor C. Dhepale, City Engg.,

(Name of Officers with designation) from Municipal Council, Mehkar, PHED

inspected the Meher International School, Mehkar

(Name & Address of the school) on 21.04.25 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 2754 dated 02.04.2025

of District Public Health Lab (PHED Lab) certified that the Meher International School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 1 year

Signature with Seal:

Name

Designation

Name & Address of the Office / Department:

Kishor Chandrabhan Dhepale
City Engg.

To Meher International School
Mehkar Dist. Buldhana
(Name & Address of the Institution)



Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

महाराष्ट्र राज्य सार्वजनिक आरोग्य सेवा

जिल्हा आरोग्य प्रयोगशाळा बुलढाणा

ई मेल : dphlbul@gmail.com

दुर्घटनी क्रमांक : 07262/299249

पाणी नमुन्याचा सूक्ष्मजीवीय अहवाल

प्रति, वृषाचार्य, महेश इंटरनेशनल स्कूल, महाराष्ट्र, जिल्हा. बुलढाणा

पाठविणाऱ्याचे पत्र क्रमांक व दिनांक :- ५७५/०२/०५/२०२५

प्रयोगशाळा संदर्भ क्रमांक :- २७५५

नमुना घेतल्याचा दिनांक :- ०२/०५/२०२५

नमुना पोहोचल्याचा दिनांक :- ०२/०५/२०२५

परिक्षण सुरू केल्याचा दिनांक :- ०२/०५/२०२५

अ.क्र.	नमुन्याचे विवरण	परिक्षणाचे निष्कर्ष			इतर अभिप्राय	
		प्रति १०० मि.ली. नमुन्यातील संभाव्य सुक्ष्मजंतूची संख्या				
		कोलीफॉर्म	थर्मोटॉलरंट जीवाणू	इ. कोलाय		
	<p>वृषाचार्य, महेश इंटरनेशनल स्कूल महाराष्ट्र ता. महाराष्ट्र ग्री. बुलढाणा व्हॅचे R.O. पाठी नमुना —</p> <p>का.पा.कृ - ८५४३५० का.त.की - ९४०१ दिनांक - ०२/०५/२५</p>	आपले पत्र क्र. ५७५/२०२५	दिनांक ०२/०५/२०२५ अन्वये	प्राप्त पाणी नमुने अ.क्र. ०० ते ०१	पिण्यास योग्य आढळले आहेत.	


अभिप्राय : पिण्यास अयोग्य पाण्यावर योग्य प्रमाणात क्लोरिनची प्रक्रिया केल्यानंतर व सुक्ष्मजीवीय पुनर्तपासणीनंतर पिण्यास योग्य असल्याची खात्री झाल्यानंतरच ते पाणी पिण्यासाठी वापरता येईल.

अहवाल क्रमांक : ११००

दिनांक :- ०७/०५/२५

प्रत सादर :-

- मा. जिल्हा आरोग्य अधिकारी, जिल्हा परिषद, बुलढाणा
- मा. जिल्हा शल्य चिकित्सक, सामान्य रुग्णालय, बुलढाणा
- मा. गटविकास अधिकारी, पंचायत समिती,


मुख्य अनुजीव शास्त्रज्ञ

जिल्हा अमुंत्रेय प्रयोगशाळा, बुलढाणा
D.P.H.I., Buldhana

State / Regional / District / Public Health Laboratory *Bulandshahr*E-mail-ID : dphlbul@gmail.com

Ref 118

Phone No. : 07262/299249

REPORT ON CHEMICAL EXAMINATION OF WATER FOR DRINKING PURPOSES

Date of Collection :— 02/04/25 Date of Receipt :— 02/04/25 Date of Examination :— 02/04/25
(All the Analytical Results are in mg/Litre except pH, Turbidity)

Sr. No.	TEST PARAMETER	(1)	(2)	(3)	BIS Specification 10500 : 2012 Normal Values	
		Mahesh LCBSE R.O. Water	International School Mehkar DIST- Bulandshahr	R.O. Water	Desirable Limits	Permissible Limits
1.	Physical Appearance	clear			—	—
2.	Odour	odourless			Agreeable	Agreeable
3.	Turbidity (as N.T.U.)	0.0			1.0	5.0
4.	pH Value	6.9			6.5 to 8.5	No relaxation
5.	Chlorides (as Cl)	19			250	1000
6.	Nitrates (as NO ₃)	ND			45	No relaxation
7.	Total Hardness (as CaCO ₃)	18			200	600
8.	Alkalinity (as CaCO ₃)	22			200	600
9.	Total Dissolved Solids	60			500	2000
10.	Iron (as Fe)	ND			0.3+	No relaxation
11.	Fluoride (as F)	ND			1.0	1.5
12.	Other Tests (if any)	ND				
13.		1				
14.						
15.						
16.						
17.						
18.						
19.						
20.						

ND - Not detected.

- This report is restricted only for the Sample/s is Submitted to this Laboratory.
- This Sample/s is / are not Collected by this Laboratory.

[P.T.O.]

REMARKS

A) Sample No. (s) 01 is/are potable / chemically fit for drinking purpose on the basis of analysed parameters only.

✓ However, this / these water source/s can be used for drinking purpose only after proper treatment, disinfection and ascertaining it's bacteriological quality frequently or regularly.

B) Sample No. (s) STANDPIPE, ROAD Contains _____

However, if there is no any other alternate source available nearby then this / these water Source/s can be used for drinking purpose only after proper treatment, disinfection and ascertaining it's bacteriological quality frequently or regularly.

C) Sample No. (s) STANDPIPE, ROAD Contains _____

Hence, this / these water Source/s is / are chemically non-potable / unfit for drinking purpose on the basis of analysed parameters only.

HEALTH SERVICES

No. DPH4/BUL/UD/1162/2025

Date :- 15/05/2025

Forwarded With Compliments To : Principal
Mahesh International School
(CBSE pattern) Nehkal
DIST Buldara

With reference to letter No. : 475/2025 Dated :- 02/04/15

Fees Rs. : 940/-

Receipt No. and Date : 854350 dt 02/4/15

Bonadane
Chief Bacteriologist
DPHL, Buldara

HEALTH AND SANITATION SELF DECLARATION CERTIFICATE

I/We hereby declare that Mahesh International School, located at Mehkar, Dist. Buldana, complies with all health, hygiene, and sanitation norms as prescribed by CBSE and the concerned local authorities.

The school affirms that:

1. The school premises, including classrooms, corridors, toilets, laboratories, library, and playground, are kept clean and hygienic.
2. Safe and adequate drinking water facilities are available for students and staff.
3. Separate and sufficient toilets for boys, girls, and staff are provided and cleaned regularly.
4. Proper waste management and garbage disposal systems are in place.
5. Adequate ventilation, lighting, and cleanliness are maintained in all rooms.
6. First-aid facilities are available and basic health records are maintained.
7. Regular awareness programs on health, hygiene, and sanitation are conducted for students and staff.
8. Necessary measures are taken to prevent the spread of communicable diseases.

I/We understand that the school is responsible for maintaining health and sanitation standards at all times and that appropriate action may be taken by CBSE or authorities in case of non-compliance.

This declaration is submitted for CBSE affiliation / inspection / official purpose.



Chairman Secretary
Mahesh Bahuddeshiya Sanstha
Mehkar Dist. Buldana